

TEST REPORT No. 068 -1 SF/16 U

page (pages)

Date: 27 of Juni 2016

1 (6)

**Determination of thermal resistance of reflective insulation product according  
LST EN 16012:2012+A1:2015\* and LST EN ISO 8990:1999**

(test title)

**Test method:** LST EN 16012:2012+A1:2015\*: Thermal insulation for buildings-Reflective insulation products-Determination of the declared thermal performance;  
LST EN ISO 8990:1999 Thermal insulation - Determination of steady-state thermal transmission properties - Calibrated and guarded hot box (ISO 8990:1994).

(number of normative document or test method, description of test procedure, test uncertainty)

**Specimen description:** Type of product: reflective insulation product  
Names of product:

- TRISO HYBRID<sup>S</sup>
- TETRIS

Nominal thickness (EN 823) – 56 mm

(name, description and identification details of a specimen)

**Customer:** ACTIS SA Avenue de Catalogne, 11300 Limoux, France

(name and address)

**Manufacturer:** ACTIS SA Avenue de Catalogne, 11300 Limoux, France

(name and address)

**Test results:**

Name of the indicator and unit	Test method reference no.	Test result
Thermal resistance $R$ , (m <sup>2</sup> ·K)/W	LST EN ISO 8990:1999	4,180
Corrected $R$ -core thermal resistance, (m <sup>2</sup> ·K)/W	LST EN ISO 16012:2012+A1:2015*	2,907
Position of specimen: vertical (direction of heat flow – horizontal)		
*flexible scope		

**Tested at:** Laboratory of Building Physics, Institute of Architecture and Construction of Kaunas  
University of Technology

(name of the test laboratory)

**Specimen delivery date:** 2016-05-19      **Date of testing:** 2016-05-27

**Sampling:** The test specimen sampled by customer. Description N<sub>o</sub>. 068-1/16-1A.

**Additional information:**

Application 2016-02-23, drawing.

(any deviations, complementary tests, exceptions and any information related with particular test)

**Annexes:**

*Annex 1.* Test results;

*Annex 2.* Parameters of Guarded Hot Box measurement;

*Annex 3.* Specimen products and air gaps thermal properties;

*Annex 4.* Perimeter zone's linear thermal transmittance value of the specimen;

*Annex 5.* Specimen design data;

*Annex 6.* Scheme of climate chamber „Hot box“.



(indicate annex numbers and titles)

Head of Laboratory:

(approves the test results)

Tested by:

(technically responsible for testing)

  
K. Banionis (n., surname)  
  
A. Burlingis (n., surname)  
S.P.

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.

**Annex 1. Test results:**

Data element	unit	Value
Air velocity on warm side, downwards, $v_1$	m/s	0,14
Air velocity on cold side, upwards, $v_e$	m/s	1,26
Total power input to metering box, $\Phi_{in}$	W	11,463
Heat flow density through a specimen, $q_{sp}$	W/m <sup>2</sup>	2,2764
Corrected heat flow density through a specimen, $q_c$	W/m <sup>2</sup>	2,3203
Warm side air temperature, $\theta_{ci}$	°C	20,36
Cold side air temperature, $\theta_{ce}$	°C	9,38
Surface temperature of the warm side, $\theta_{ni}$	°C	19,649
Surface temperature of the cold side, $\theta_{ne}$	°C	9,949
Temperature difference, $\Delta T$	°C	9,700
Thermal resistance of specimen, $R$	m <sup>2</sup> ·K/W	4,180
Corrected, thermal resistance of specimen, $R_{core}$	m <sup>2</sup> ·K/W	2,650
Uncertainty of the measurement, $\Delta R$	m <sup>2</sup> ·K/W	± 0,18025

Tested by: A. Burlingis



Date: 2016-05-27

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.

**Annex 2. Parameters of Guarded Hot Box measurement.**

**Table 1. TRISO HYBRID<sup>S</sup> insulation system's specimen measured at 20°C/10°C temperature regime**

<i>Guarded Hot Box measurement. Parameters of "TRISO HYBRID<sup>S</sup>" insulation system's specimen:</i>										
Specimen's area A, m <sup>2</sup>		1,831		Actual mean thickness of specimen, mm		≈ 148*				
Position of a specimen		vertical		Length of specimen perimeter L, m		5,44				
				Linear thermal transmittance of perimeter zone Ψ <sub>L</sub> , W/(m·K)		-0,001525				
<i>Measurement data:</i>										
<i>Insulation system with product "TRISO HYBRID<sup>S</sup>":</i>										<i>Result:</i>
Sample No.	Temperature regime, °C	Hot side ambience temperature t <sub>h</sub> , °C	Hot side surface temperature τ <sub>h</sub> , °C	Cold side ambience temperature t <sub>c</sub> , °C	Cold side surface temperature τ <sub>c</sub> , °C	Temperature difference Δt = (t <sub>h</sub> - t <sub>c</sub> ), °C	Temperature difference Δτ = (τ <sub>h</sub> - τ <sub>c</sub> ), °C	Measured heat flow density q, W/m <sup>2</sup>	Corrected heat flow density q <sub>c</sub> , W/m <sup>2</sup>	R-value of insulation system, m <sup>2</sup> ·K/W
1	20 /10	20,377	19,6488	9,451	9,9492	10,925	9,6995	2,2764	2,3203	4,180±0,180

\* Previous test has shown that when installed on real building the average thickness of product is slightly larger than its nominal value. To keep surfaces of test sample as parallel as possible in the test setup, it is decided to install the product in a frame. After internal validation, the thickness of the frame is representative of the average thickness of an installed product, as requested by LST EN ISO 8990.

**Annex 3. Specimen product and air gaps thermal properties**

**Table 2. TRISO HYBRID<sup>S</sup> insulation specimen product R-core value measurement results**

Product	Thickness, d mm	Hot side temperature τ <sub>h</sub> , °C	Cold side temperature τ <sub>c</sub> , °C	Temperature difference Δτ, °C	Heat flow density q <sub>c</sub> , W/m <sup>2</sup>	Product's R-core value, m <sup>2</sup> ·K/W
TRISO HYBRID <sup>S</sup>	88	17,9470	11,7985	6,1485	2,3203	2,650

Note: the mean temperature at each surface is derived from 12 measuring points.

**Table 3. TRISO HYBRID<sup>S</sup> insulation specimen air gaps corrected R-core values calculation results according to LST EN 16012:2012+A1:2015 and LST EN ISO 6946:2008**

Air gap number	Thickness d, mm	Measured temperature differences of surfaces, Δτ, °C	Radiative heat transfer coefficient, h <sub>r</sub>	Convective heat transfer coefficient, h <sub>a</sub>	Air gap R-core value, m <sup>2</sup> ·K/W
Air gap #1	30	1,7018	0,3352	1,25	0,6308
Air gap #2	30	1,8493	0,3069	1,25	0,6423

**Table 4. TRISO HYBRID<sup>S</sup> insulation specimen products**


Specimen product	Specimen surface layer	Test method reference No.	Declared emissivity, ε
TRISO HYBRID <sup>S</sup>	HQ2000+LAQUE	EN 16012	0,06 *
	HQ2000+LAQUE		0,06 *

\* Emissivity results by Forschungsinstitut für Wärmeschutz e.V. München Tests Reports No. D3-06/11  
R-core thermal resistance value calculation according to LST EN 16012:2012+A1:2015:

$$R_{\text{core}} (\text{LST EN 16012:2012+A1:2015}) = 4,180 - 0,6308 - 0,6423 = 2,9071 (\text{m}^2 \cdot \text{K})/\text{W}$$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.

**Annex 4. Perimeter zone's linear thermal transmittance value of the specimen**



Effective thermal conductivity of product  $\lambda_{eff} = 0,03321 \text{ W}/(\text{m}^2 \cdot \text{K})$

Perimeter zone's  $U$ -value:  $0,2071 \text{ W}/(\text{m}^2 \cdot \text{K})$ ; width "d" – 250 mm;

Central area  $U$ -value:  $0,2132 \text{ W}/(\text{m}^2 \cdot \text{K})$ .

Perimeter's linear thermal transmittance:  $\psi = (0,2071 - 0,2132) \cdot 0,25 = -0,001525 \text{ W}/(\text{m} \cdot \text{K})$ .

The correction of measured heat flow density value due to perimeter zone is calculated according to equation:

$$q_c = \frac{Q_c}{A} = \frac{Q - \psi \cdot L \cdot \Delta t}{A} = \frac{q \cdot A - \psi \cdot L \cdot \Delta t}{A} = q - \psi \cdot \left( \frac{L \cdot \Delta t}{A} \right);$$

here:

$A$  – area of a specimen,  $\text{m}^2$ ;

$Q$  – measured mean heat flow through a specimen,  $\text{W}$ ;

$q$  – measured mean heat flow density through a specimen,  $\text{W}/\text{m}^2$ ;

$Q_c$  – corrected mean heat flow through a central area of specimen,  $\text{W}$ ;

$q_c$  – corrected mean heat flow density through a central area of specimen,  $\text{W}/\text{m}^2$ ;

$L$  – perimeter length of a specimen,  $\text{m}$ ;

$\Delta t$  – ambient temperature difference across a specimen,  $\text{K}$ ;

$\psi$  – perimeter's linear thermal transmittance of a specimen,  $\text{W}/(\text{m} \cdot \text{K})$ .


Corrected  $R$ -value:  $R_c = \frac{\Delta \tau}{q_c}$ ;

$\Delta \tau$  – temperature difference across a specimen,  $\text{K}$ .

Validity – the named data and results refer exclusively to the tested and described specimens.

Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.


**Annex 5. Specimen design data**



1.	OSB 5 mm
2.	Air gap 30 mm (#1)
3.	TRISO HYBRID <sup>S</sup> 88 mm
4.	Air gap 30 mm (#2)
5.	OSB 5 mm
6.	XPS (extruded polystyrene)
7.	XPS (extruded polystyrene)
8.	plywood

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.

*Annex 6. Scheme of climate chamber „Hot box“*



1. Warm side guard box:
  - internal dimensions 2800 × 2800 × 1100 mm;
  - wall thickness 130 mm, total thermal resistance about 3 m<sup>2</sup>·K/W.
2. Guard air flows deflecting screen.
3. Electrical heater, power 660 W, controlled according to a set point temperature in metering box (6).
4. Electrical heater of metering box, power control from 13W to 660 W.
5. Warm side baffle (of metering box) with surface and air temperature sensors.
6. Metering box – internal dimensions 2400 × 2400 × 360 mm.
7. Surround panel: 200 mm thick, core material EPS polystyrene (faced with 3 mm thick cellular PVC plastic sheet on either side), thermal resistance about 6 m<sup>2</sup>·K/W, 1484 x 1234 mm aperture for specimen mounting.
8. Cold side box:
  - internal dimensions 2800 × 2800 × 1100 mm;
  - wall thickness 130 mm, total thermal resistance about 3 m<sup>2</sup>·K/W.
9. Cold side baffle with surface and air temperature sensors.
10. Cold side box controlled
11. Cold side controlled cooling air unit, max. cooling power up to 3 kW.
12. Cold side air cooling box with 5 speed motor fan. electrical heater, max. power 2 k

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Science Laboratory of Building Thermal Physics.